




2017 WASTEWATER SUMMERY REPORT

WASTEWATER TREATMENT AND COLLECTION

JANUARY 1, 2017 THROUGH DECEMBER 31, 2017

PUBLIC WORKS DEPARTMENT – TOWN OF ST. MARYS



FACILITY FACTS

Facility: *Anoxic/Oxic Biological Nutrient Removal (A/O BNR) System with Integrated Sludge Management*

ECA: 4934-AH9S98 (issued February 24, 2017)

Design Capacity:

Average Daily Flow: 5,560 m³/day

Peak Daily Flow: 14,250 m³/day

Facility Classification

Treatment Plant: Wastewater Treatment 3 [WWT3] (Revised Sept. 7, 2017)

Collection System: Wastewater Collection 2 [WWC2]

Receiving Water: Thames River – North Branch

Table of Contents

1.0	SYSTEM OVERVIEW	4
2.0	SUMMARY OF MONITORING DATA.....	6
2.1	Wastewater Monitoring.....	6
3.0	EFFLUENT QUALITY ASSURANCE	12
4.0	MAINTENANCE ACTIVITIES [PLANNED / UNPLANNED]	12
5.0	FUTURE ALTERATIONS	13
6.0	CALIBRATION AND MAINTENANCE PROCEDURES	13
7.0	BIOSOLIDS.....	13
8.0	BY-PASS, SPILLS OR ABNORMAL DISCHARGE	14
9.0	NOTICE OF MODIFICATIONS.....	14
10.0	REMOVAL RATES	14

APPENDIX A MONITORING DATA

APPENDIX B WMS REPORT

APPENDIX C NOTICE OF MODIFICATIONS

1.0 SYSTEM OVERVIEW

The St. Marys Wastewater Treatment Plant completed a Sludge Management Upgrade in 2010. The upgrade included conversion of the existing extended aeration activated sludge type system to an anoxic/oxic biological nutrient removal system with integrated sludge management. The system consists of the following:

Raw Sewage Conveyance:

Raw sewage typically flows by gravity throughout the system to the wastewater treatment plant. Where gravity flow is not possible due to elevation restrictions, raw sewage flows by gravity to each of the three pump stations that service the Town of St. Marys and from there is pumped to the wastewater treatment plant. The three pump stations are located as follows:

- Emily Street Pump Station consisting of 2, 30 HP pumps controlled by floats with high level float alarm.
- Robinson Street Pump Station consisting of 2, 7.5 HP pumps controlled by milltronics with high level float alarm and an emergency back-up generator.
- Queen Street Pump Station consisting of 2, 10 HP pumps controlled by milltronics with high level float alarm and an emergency back-up generator.

Inlet Works:

Sewage flows from the collection system and the three pump stations into the wet well through automatic bar screens then through a grit tank and communiton, the grit is conveyed to a bin sent to landfill. Sewage then flows by sewer piping to the anoxic tanks.

Anoxic Tanks:

Sewage is split between two round tanks with submersible mixers.

Aeration Tanks:

Sewage enters an inlet chamber where flows are split to three distribution chambers which feed three aeration basins operating in parallel. In 2015 there was a 150 HP turbo blower installed to provide a minimum 2,506 m³ of air/hour to replace one of the centrifugal blowers.



Secondary Clarifiers:

Sewage is split into four centre feed round clarifiers, two of which are presently in operation. During high flow conditions the other two clarifiers are put into service. Return activated sludge collected here can be transferred from the clarifiers to the aeration or waste activated equalization tanks which are the holding tanks for the sludge thickening process.

Disinfection and Discharge:

Effluent passes through two ultraviolet lamp arrays containing a total of 112 lamps. A sodium hypochlorite liquid feed system is provided for backup chlorination in the event of UV failure. Final effluent is discharged via pipe to the outfall on the bank of the Thames River.

Biosolids Handling

Waste activated sludge is pumped from the WASEQ tanks (waste activated sludge equalization) into two sludge storage tanks that were previously used as digesters. Supernate is taken off the top of the storage tanks to thicken the sludge. The sludge from these storage tanks is then dosed with polymer and then processed through the centrifuge. The dewatered sludge produced by the centrifuge is then run through the Lystek process. The Biosolids are then mixed with potassium hydroxide in a heated mixing tank and processed.

Product from the mixing tank is pumped to a mixed storage tank equipped with an activated carbon odour control system. Biosolids are loaded to the tanker from an overhead hose. The loading area is equipped with curbing and graded to catch basins tied into the Works.



Lystek Process



Lystek Chemical Feed System

Phosphorus Removal:

One phosphorus removal system capable of processing internal recycle streams consisting of one polymerized aluminum sulphate feed system consisting of two chemical feed pumps discharging into the channel of the outlet of the aeration tanks.

Standby Power

The wastewater treatment plant has an automatic standby generator which will operate the plant when there is a power failure. This allows for manual running of the plant when power outages occur.

2.0 SUMMARY OF MONITORING DATA

The St. Marys Wastewater Treatment Plant was monitored as per the Environmental Compliance Approval #4934-AH9S98.

Detailed monitoring data is supplied in Appendix A.

2.1 Wastewater Monitoring

The raw wastewater is monitored for BOD₅, total suspended solids, total phosphorus, total ammonia nitrogen, alkalinity and total kjeldahl nitrogen weekly by composite sample. E-coli is monitored weekly by a grab sample. Dissolved oxygen, PH and temperature are monitored daily Monday to Friday. The plant was designed based on typical raw water characteristics.

Effluent is sampled on a weekly basis and tested for CBOD5, suspended solids, total phosphorus and total ammonia nitrogen as a composite sample. A grab sample is taken weekly and tested for E. coli. Unionized ammonia is calculated weekly. These parameters specified in the ECA were analyzed by SGS Lakefield; which is an accredited laboratory in Ontario. In-house tests are conducted by licensed operators for monitoring purposes using Standard Methods and the data generated from these tests is used to determine the treatment efficiency while maintaining process control; these include pH, temperature and DO which is mandatory Monday to Friday as well as phosphorus, ammonia, total suspended solids and settling tests. These tests will help the operators to meet the effluent objectives and limits by adjusting processes.

Refer to **Appendix A** for more detailed monthly results.


There was a Ministry of Environment and Climate Change Inspection on November 29, 2017. There has not been a finalized report at this time.

The total flow treated at the treatment plant was 1,542,384 m³. The average daily flow for raw wastewater was 4,225.71 m³/d. This represents 76% of the design capacity of 5,560 m³/d. The maximum daily flow was 13,055 m³ which occurred on May 5, 2017. This was related to heavy rains.


There were 51 instances where the rated capacity of 5,560 m³/day was exceeded, these occurred in the months of January, February, March, April, May, June, July and November and were related to wet weather conditions. The peak flow rate of 14,250 m³ was not exceeded in 2017.

According to the Stratford weather station in 2017, there was a total of 912.6 mm of rain and 673.6 mm in 2016. Total snow in 2017 was 122.5 cm and 233 cm in 2016.

Rain Precipitation




Snow Accumulation




The Wastewater Treatment Plant (WWTP) is designed to handle a soluble BOD of 100 mg/L and a total BOD of 300 mg/L. The annual average raw sewage BOD₅ concentration to the plant was 312.1 mg/L with a maximum daily concentration of 630 mg/L. The annual average final effluent CBOD₅ concentration was 3.9 mg/L with a maximum daily concentration of 10 mg/L.

Effluent - CBOD5 (mg/L) ECA Monthly Limit - 15



Effluent - CBOD5 (mg/L) ECA Daily Limit - 25




*Objectives – The owner shall use best effort to operate the works with in the objectives

**Limits – The owner shall operate and maintain the works such that the concentrations of the parameters are not exceeded in the effluent

The annual average raw sewage total suspended solids (TSS) concentration to the plant was 216.13 mg/L, with a maximum daily concentration of 772 mg/L. The annual average final effluent TSS concentration was 6.5 mg/L with a maximum concentration of 15 mg/L. Efforts are made by the operators to maintain the solids below the objectives by monitoring the process closely and making adjustments as required.


Effluent - Total Suspended Solids (mg/L)

ECA Monthly Limit - 15



Effluent - Total Suspended Solids (mg/L)

ECA Daily Limit - 25




*Objectives – The owner shall use best effort to operate the works with in the objectives

**Limits – The owner shall operate and maintain the works such that the concentrations of the parameters are not exceeded in the effluent

The annual average raw sewage total phosphorus (TP) concentration to the plant was 4.12 mg/L with a maximum daily concentration of 10.7 mg/L. The annual average final effluent TP concentration was 0.37 mg/L with the maximum being 0.92 mg/L. Efforts are made by the operators to maintain the total phosphorus below the objectives by monitoring the process closely and making chemical and process adjustments as required.


Effluent - Total Phosphorus (mg/L)

ECA Monthly Limit - 1.0



Effluent - Total Phosphorus (mg/L)

ECA Daily Limit - 1.0




*Objectives – The owner shall use best effort to operate the works with in the objectives


**Limits – The owner shall operate and maintain the works such that the concentrations of the parameters are not exceeded in the effluent

The annual average raw sewage total ammonia nitrogen concentration to the plant was 28.78 mg/L with a maximum daily concentration of 36.7 mg/L. The annual final effluent total ammonia nitrogen concentration was 0.13 mg/L with a maximum daily concentration of 0.60 mg/L.

Effluent - Total Ammonia Nitrogen (mg/L) ECA Monthly Limit - 6.0



Effluent - Total Ammonia Nitrogen (mg/L) ECA Daily Limit - 8.0



*Objectives – The owner shall use best effort to operate the works with in the objectives

**Limits – The owner shall operate and maintain the works such that the concentrations of the parameters are not exceeded in the effluent

There were no formal odour complaints in 2017 however, the Town of St. Marys is aware of odour issues associated with the WWTP and is currently investigating options to reduce odour sources. The Town did receive notice regarding odour concerns from a nearby business, however notice was typically provided after the event which limited ability to investigate and attribute the source to the facility.

3.0 EFFLUENT QUALITY ASSURANCE

Effluent quality assurance is evaluated by monitoring parameters and changes throughout the plant processes. The operators monitor the basins by performing tests on the mixed liquor. These tests include dissolved oxygen, pH, temperature, settling tests, Mixed Liquor Suspended Solids (MLSS). As well, monitoring of the aluminum sulfate dosages and wasting volumes are completed. Data collected from these tests provide valuable information to the operator to make the appropriate adjustments in the treatment process and take corrective actions before the plant reaches its effluent limits.

All in-house monitoring equipment is calibrated based on the manufacturer's recommendations.

Annually a facility sampling schedule calendar is prepared and reviewed with operational staff; the sampling schedule calendar identifies sample collection dates to meet regulatory requirements of the ECA.

4.0 MAINTENANCE ACTIVITIES [PLANNED / UNPLANNED]

Regular scheduled monthly preventative maintenance is assigned and monitored using the Workplace Management System (WMS) program. The Work Management System (WMS) provides the framework of how OCWA manages and plans work such as maintenance and operational activities, and is the framework which is supported within our CMMS. (Computerized Maintenance Management System)

A method to prioritize maintenance requests is required to ensure that the top priority work is being pursued at all times. A method has been developed that balances risk, safety, environmental, customer, operations, financial and urgency factors and can be used by maintenance request initiators, maintenance planners and workers to ensure that the right work is being completed at the right time.

The result of this maintenance work prioritization is a plan for which resources can be prepared and allocated in an efficient manner.

OCWA's WMS uses data to support how work orders are scheduled. Work orders are prioritized according to the following three classifications:

1. **Emergency work** usually involves safety hazards, environmental concerns or major interruption of service. Repairs are generally initiated without waiting for work orders to be processed.
2. **Routine/Preventive maintenance work** does not require prioritizing, as it is always scheduled.
3. **Breakdown/Corrective maintenance work** is prioritized, planned and scheduled into the regular preventive maintenance program.

The preventive maintenance requirement is built into the regular work schedule and corrective maintenance work requests are added to the schedule according to the priority and workload of staff and availability of outside contractors. The following are the number of work orders generated and completed in 2017.

Preventative Maintenance Work Orders Generated											
Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
50	54	42	49	49	65	46	61	53	47	43	55

For a summary of the maintenance performed please see Appendix B – WMS reports.

5.0 FUTURE ALTERATIONS

The Town of St. Marys, in collaboration with Ontario Clean Water Agency continue to investigate potential future alterations for the facility. Future alterations are being governed by a long term capital needs projection which covers a 20-year planning period. Planned future alterations or upgrades in the next few years consist of, but are not limited to:

- Replace diesel generator to run the sewage plant and administration building;
- Replace the diesel generator at the Queen Street Pump Station;
- Engineering Design for replacement Grit Removal, Odour Control and Administration Building;
- Construction of a new Grit Removal, Odour Control and Administration Building;
- Replace or rehabilitate Supernate well.

6.0 CALIBRATION AND MAINTENANCE PROCEDURES

In 2017 calibrations were completed by Pierce Services and Solutions Inc. for the flow meters at the facility. Pierce also calibrated all hand held and laboratory equipment. The backflow preventers were done by Curney Mechanical. Kone Cranes did the inspection of all lifting equipment/devices. Hetek Solutions Inc. calibrated all gas monitoring equipment and replace faulty sensors as required. Sommers did the inspection of the emergency generator. Mobile Fire and Safety completed the inspection of all fire extinguishers. In-house meters for pH and dissolved oxygen are calibrated by OCWA operators as per manufacturer's instructions. Other annual maintenance items include annual boiler inspections and UV inspection and maintenance by H2Flow.

Other maintenance that occurred in 2017 include: replaced the transfer switch for Queen St. pump station generator, installation of check valve for return sludge pump, replaced discharge hose for alum pump, replaced/repaired backflow preventers in sludge building, Lystek building and blower building, replaced polymer injector in Lystek building, replaced contactors on relay for pump at Queen St. pump station, replaced heating element and actuator in steam boiler for Lystek, replaced wear rings in activated sludge pumps #1, # 3 and #5, repaired the waterline to activated sludge pump #3, replaced batteries in UPS, repairs to waste activated sludge mixer, re-built raw sewage pump #3, repairs to the chains on the bar screens for the raw sewage, repairs to ventilation system in blower room, installed heat tracing to blower intake to prevent freezing.

7.0 BIOSOLIDS

Biosolids produced at the St. Marys WWTP are from the Lystek System which result in a federally registered fertilizer product. In the summer of 2016, Lystek International Inc. (Lystek) entered into a five (5) year agreement with the Town for marketing and management of the LysteGro fertilizer produced from the facility.

During five (5) application events in the summer and fall of 2017, a total of 3,980 cubic metres of material was land applied. Of that 3,980 cubic metres, 3,408 cubic metres was produced in 2017 with the remaining 472 cubic metres having been produced in 2016 and placed in storage until land application was available. It is estimated that approximately 4000 cubic metres will be produced in 2018. All bio-solids sample analysis was carried out by SGS Lakefield Research Ltd.

The 2017 application season was a success for the St. Marys material which was marketed effectively and applied responsibly as a fertilizer. All hauling and application of material was completed according to best practices in terms of nutrient management and in an economical fashion.

8.0 BY-PASS, SPILLS OR ABNORMAL DISCHARGE

There were no abnormal discharge events for 2017.

9.0 NOTICE OF MODIFICATIONS

Limited operational flexibility allows for the sewage works under the current ECA to do certain modifications to the sewage works in accordance with the Terms and Conditions of the ECA.

There was one Notice of Modification that was prepared in relation to the new 40 HP progressive cavity sludge pump that was installed in the sludge storage tank for sludge removal.

The pump was commissioned on September 28, 2017 and is now operational.

A copy of this notice can be found in **Appendix C** of this report.

10.0 REMOVAL RATES

Removal rates for CBOD₅, TSS, and Total Phosphorus were all 97% or better for 2017.

Removal rates were as follows: CBOD₅ (99.3%), TSS (98.4%) and Total Phosphorus (97.1%).

REPORT PREPARED BY:

Renee Hornick
Senior Operations Manager
Ontario Clean Water Agency

REPORT REVIEWED BY:

Dave Blake, C.E.T.
Environmental Services Supervisor
Town of St. Marys



Wastewater Annual Summary Report
Reporting Year - 2017

APPENDIX A
MONITORING DATA

Ontario Clean Water Agency
Performance Assessment Report Wastewater/Lagoon

From: 01/01/2017 to 31/12/2017

Facility: ST MARYS WASTEWATER TREATMENT FACILITY

Works: [110001275]

	01/2017	02/2017	03/2017	04/2017	05/2017	06/2017	07/2017	08/2017	09/2017	10/2017	11/2017	12/2017	<--Total-->	<--Avg.-->	<--Max.-->
Flows:															
Raw Flow: Total - Raw Sewage (m³)	178439.00	134668.00	161225.00	154225.00	181256.00	114943.00	108223.00	93056.00	90649.00	94749.00	123157.00	107794.00	1542384.00		
Raw Flow: Avg - Raw Sewage (m³/d)	5756.10	4809.57	5200.81	5140.83	5846.97	3831.43	3491.06	3001.81	3021.63	3056.42	4105.23	3477.23		4228.26	
Raw Flow: Max - Raw Sewage (m³/d)	11969.00	6633.00	10353.00	7247.00	13055.00	5920.00	6770.00	3469.00	4158.00	3464.00	6225.00	4573.00			13055.00
Eff. Flow: Total - Final Effluent (m³)	175324.00	141919.00	177142.00	180517.00	200202.00	127742.00	120341.00	81941.00	79312.00	90248.00	103722.00	93959.00	1572369.00		
Eff. Flow: Avg - Final Effluent (m³/d)	5655.61	5068.54	5714.26	6017.23	6458.13	4258.07	3881.97	2643.26	2643.73	2911.23	3457.40	3030.94		4311.70	
Eff. Flow: Max - Final Effluent (m³/d)	10030.00	6766.00	9845.00	7694.00	12232.00	5755.00	6444.00	3312.00	2893.00	3763.00	4832.00	3427.00			12232.00
Carbonaceous Biochemical Oxygen Demand: CBOD:															
Eff: Avg cBOD5 - Final Effluent (mg/L)	< 2.600	< 3.750	< 4.750	< 2.750	< 3.000	3.250	< 3.250	< 2.800	2.750	< 3.400	< 4.500	4.500		< 3.442	4.750
Eff: # of samples of cBOD5 - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Loading: cBOD5 - Final Effluent (kg/d)	< 14.705	< 19.007	< 27.143	< 16.547	< 19.374	13.839	< 12.616	< 7.401	7.270	< 9.898	< 15.558	13.639		< 14.750	27.143
Biochemical Oxygen Demand: BOD5:															
Raw: Avg BOD5 - Raw Sewage (mg/L)	242.600	263.500	326.750	285.000	243.800	379.000	370.000	289.600	390.250	407.000	242.250	305.500		312.104	407.000
Raw: # of samples of BOD5 - Raw Sewage (mg/L)	5	4	4	4	5	5	4	5	4	5	4	4	53		
Eff: Avg BOD5 - Final Effluent (mg/L)	< 3.000	< 4.500	< 6.250	< 3.000	3.800	< 3.500	< 4.500	< 3.200	2.750	< 3.600	< 4.000	5.000		< 3.925	6.250
Loading: BOD5 - Final Effluent (kg/d)	< 16.967	< 22.808	< 35.714	< 18.052	24.541	< 14.903	< 17.469	< 8.458	7.270	< 10.480	< 13.830	15.155		< 17.137	35.714
Percent Removal: BOD5 - Raw Sewage (mg/L)	98.763	98.292	98.087	98.947	98.441	99.077	98.784	98.895	99.295	99.115	98.349	98.363			99.295
Total Suspended Solids: TSS:															
Raw: Avg TSS - Raw Sewage (mg/L)	202.000	248.000	193.250	218.500	222.200	240.800	210.750	228.800	201.500	157.800	184.250	285.750		216.133	285.750
Raw: # of samples of TSS - Raw Sewage (mg/L)	5	4	4	4	5	5	4	5	4	5	4	4	53		
Eff: Avg TSS - Final Effluent (mg/L)	5.800	4.000	8.000	5.750	4.200	7.250	9.000	6.800	5.250	6.000	6.250	10.000		6.525	10.000
Eff: # of samples of TSS - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Loading: TSS - Final Effluent (kg/d)	32.803	20.274	45.714	34.599	27.124	30.871	34.938	17.974	13.880	17.467	21.609	30.309		27.297	45.714
Percent Removal: TSS - Raw Sewage (mg/L)	97.129	98.387	95.860	97.368	98.110	96.989	95.730	97.028	97.395	96.198	96.608	96.500			98.387
Total Phosphorus: TP:															
Raw: Avg TP - Raw Sewage (mg/L)	3.318	3.363	2.930	3.433	3.376	4.564	4.623	4.362	4.903	5.018	4.048	5.472		4.117	5.472
Raw: # of samples of TP - Raw Sewage (mg/L)	5	4	4	4	5	5	4	5	4	5	4	4	53		
Eff: Avg TP - Final Effluent (mg/L)	0.126	0.328	0.245	0.298	0.318	0.498	0.475	0.786	0.380	0.546	0.250	0.158		0.367	0.786
Eff: # of samples of TP - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Loading: TP - Final Effluent (kg/d)	0.713	1.660	1.400	1.790	2.054	2.118	1.844	2.078	1.005	1.590	0.864	0.477		1.466	2.118
Percent Removal: TP - Raw Sewage (mg/L)	96.203	90.260	91.638	91.333	90.581	89.099	89.724	81.981	92.249	89.119	93.823	97.122			97.122
Nitrogen Series:															
Raw: Avg TKN - Raw Sewage (mg/L)	25.580	25.050	23.550	23.000	23.240	30.200	29.925	32.500	31.325	33.300	28.250	39.400		28.777	39.400
Raw: # of samples of TKN - Raw Sewage (mg/L)	5	4	4	4	5	5	4	5	4	5	4	4	53		
Eff: Avg TAN - Final Effluent (mg/L)	< 0.120	< 0.175	< 0.100	< 0.150	< 0.100	< 0.100	< 0.100	< 0.120	< 0.100	< 0.140	< 0.100	< 0.250		< 0.130	< 0.250
Eff: # of samples of TAN - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Loading: TAN - Final Effluent (kg/d)	< 0.679	< 0.887	< 0.571	< 0.903	< 0.646	< 0.426	< 0.388	< 0.317	< 0.264	< 0.408	< 0.346	< 0.758		< 0.549	< 0.903
Eff: Avg NO3-N - Final Effluent (mg/L)	8.748	8.220	7.490	6.753	5.820	6.150	5.738	6.636	4.733	5.634	6.998	7.180		6.675	8.748
Eff: # of samples of NO3-N - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Eff: Avg NO2-N - Final Effluent (mg/L)	< 0.066	< 0.053	0.055	< 0.055	< 0.030	< 0.030	< 0.040	< 0.030	< 0.175	< 0.084	< 0.035	< 0.183		< 0.070	0.183
Eff: # of samples of NO2-N - Final Effluent (mg/L)	5	4	4	4	5	4	4	5	4	5	4	4	52		
Disinfection:															
Eff: GMD E. Coli - Final Effluent (cfu/100mL)	20.373	18.795	9.272	2.828	9.551	3.776	3.130	4.919	2.000	9.579	9.587	10.767		8.715	20.373
Eff: # of samples of E. Coli - Final Effluent (cfu/100mL)	5	4	4	4	5	5	4	5	4	5	4	4	53		

Final Effluent / Dissolved Oxygen: DO - mg/L																
Count	21	19	23	19	22	22	20	22	20	21	21	19	249			
Max	18.1	18.0	20.0	24.4	21.1	13.5	8.9	8.9	11.3	13.5	16.9	18.7				24.4
Mean	16.6	16.3	16.3	16.2	14.4	10.8	7.7	7.6	9.0	11.5	13.5	14.4				12.8
Min	14.9	14.1	13.9	10.8	10.5	7.5	6.1	6.6	6.6	8.8	11.0	11.8				
Final Effluent / pH																
Count	21	19	23	19	22	22	20	22	20	21	21	19	249			
Max	8.1	7.7	8.1	7.9	7.9	8.0	8.8	8.2	22.1	8.2	7.3	7.4				
Mean	6.9	7.3	7.3	7.3	7.5	7.5	7.6	7.2	8.2	7.2	7.0	7.2				
Min IH	6.6	7.0	6.7	6.7	7.0	7.1	7.1	6.9	6.1	6.9	6.8	7.0				
Final Effluent / Temperature - °C																
Count	21	19	23	19	22	22	20	22	20	21	21	19	249			
Max	16	15	19	17	25	23	25	23	23	22	18	19				
Mean	14	13	14	14	16	20	22	21	21	18	15	15				
Min	11	10	11	12	11	17	19	19	18	16	11	13				



Wastewater Annual Summary Report

Reporting Year - 2017

APPENDIX B

WMS REPORT

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
222792 Sampler 01 Raw Influent Service (1y) 5520	5520-WWSM-P-PC	0000277891	TANGENO1-A
222990 Blower Centrifugal 02 Aeration Insp/Service (1y) 5520	5520-WWSM-P-ST-AERA	0000065473	BLOWER06
222998 Blower Centrifugal 03 Aeration Insp/Service (1y) 5520	5520-WWSM-P-ST-AERA	0000065477	BLOWER06
223009 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
223014 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
223019 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
223363 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
223368 Supervisor Spot Checks (3m) 5520	5520-WWSM		H&SINS06-A
223370 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
223375 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
223380 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
223385 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
223390 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
223395 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
223400 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
223405 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
223858 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
223877 Grinder Communiton 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
223889 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
223899 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
223909 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
223919 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
223926 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
223933 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
223952 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
223962 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
223972 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
223982 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
223988 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
224412 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTURO2M
224519 OG35 FEP Review (1y) 5520	5520-WWSM		FEPRREV01-A
224559 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
224575 Flame Arrestor Service (1y) 5520	5520-WWSM		FLAMEARR-A
224589 Operation SOP Manual Review and Update (2y) 5520	5520-WWSM		SOPREV01-B
224668 WHMIS/MSDS/NSF Review and Update (1y) 5520	5520-WWSM		NSFREV01-A
225095 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
242368 Review General Data WISKI (3m) 5520	5520-WWSM		GENDATO1-Q
242425 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
250387 Lifting Device Route (1y) 5520	5520-WWSM		LIFDEV01-A
250547 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M

Work Order List

Site: OCWASITE

Work Order Description	Location	Asset	Job Plan
250552 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
250557 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
250562 Pump Cent Sludge Loading Insp/Service (1y) 5520	5520-WWSM-P-SH-DGST	0000065313	PUMCEN09A
250852 MSDS Review - (6m) 5520	5520-WWSM		MSDSREV01
250859 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
250864 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
250869 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
250874 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
250879 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
250884 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
250889 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
250894 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
250899 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
251338 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
251357 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
251369 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
251379 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
251389 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
251399 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
251406 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
251413 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
251432 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
251442 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
251452 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
251462 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
251468 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
251840 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTURQ02Q
251964 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
252001 OG111 OCWA's Fleet Policy Review (1y) 5520	5520-WWSM		FACOG111
252052 OG109 OCWAs PPE Policy Review (1y) St Marys	5520-WWSM		FACOG109
252261 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
264075 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
265095 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
273307 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
273312 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
273317 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
273322 Sampler 01 Auto Effluent Insp/Service (1y) 5520	5520-WWSM-P-PC	0000157008	SAMEFF02
273542 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
273547 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
273552 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
273557 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
273562 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
273567 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
273572 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
273577 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
273582 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
273984 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
274003 Grinder Commminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
274015 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
274025 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
274035 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
274045 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
274052 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
274059 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
274078 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
274088 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
274098 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
274108 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
274114 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
274485 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02M
274602 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
274816 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
288199 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
289362 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
298416 Conveyor 01 Rake Grit Insp/Service (1y) 5520	5520-WWSM-P-HW	0000065331	CONSCR01-A
298426 Mixer 01 Grit Organic Pump Insp/Service (1y) 5520	5520-WWSM-P-HW	0000065334	MIXSUB01-A
298432 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
298437 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
298442 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
298447 Screen 01 Detroiter Tank Components Insp/Service (1y) 5520	5520-WWSM-P-HW	0000065337	SCRTRA00-A
298722 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
298727 Chemical System Flushing (6m) 5520	5520-WWSM		CHEMFLSH01
298730 Supervisor Spot Checks (3m) 5520	5520-WWSM		H&SINS06-Q
298732 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
298737 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
298742 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
298747 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
298752 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
298757 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
298762 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
298767 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
299272 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
299291 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
299303 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
299313 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
299323 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
299333 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
299340 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
299347 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
299366 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCENO9M
299376 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCENO9M
299386 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCENO9M
299396 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB-A
299399 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
299777 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02M
299934 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
299953 OG12 Valve or Meter Chamber Inspection (1y) 5520	5520-WWSM		FACOG12
300290 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
314637 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
315397 Blower Room Cleaning 5520	5520-WWSM-F		
315398 Wasting Sink Insulation Repair 5520	5520-WWSM-F		
315399 Old Chlorine Building Tire Removal 5520	5520-WWSM-F		
315421 UV Building Cleanup 5520	5520-WWSM-F-BG		
315432 Blower Room Basement Cleaning 5520	5520-WWSM-F-BG		
315433 Screens Room Cleaning 5520	5520-WWSM-F-BG		
315434 Blower Room Cleaning 5520	5520-WWSM-F-BG		
315435 UV Building Safety Supply Organization 5520	5520-WWSM-F-BG		
315583 Review General Data WISKI (3m) 5520	5520-WWSM		GENDAT01-Q
315640 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
323460 Meter Flow Effluent Bypass Insp/Service (1y) 5520	5520-WWSM-P-PC	0000157005	METFLO01-A
323465 Meter Flow Fit1 RAS Insp/Service (1y) 5520	5520-WWSM-P-PC	0000065597	METFLO01-A
323470 Meter Flow RAS Insp/Service (1y) 5520	5520-WWSM-P-PC	0000065564	METFLO01-A
323475 Meter Flow Velocity Final Effluent Insp/Service (1y) 5520	5520-WWSM-P-PC	0000157006	METFLO01-A
323483 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
323488 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
323493 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
323498 Pump Subm P-23 Supernate Insp/Service (1y) 5520	5520-WWSM-P-TT	0000157001	PUMSUB01-A
323507 Pump Subm P-24 Supernate Insp/Service (1y) 5520	5520-WWSM-P-TT	0000157002	PUMSUB01-A
323516 Pump Subm Sludge Loading Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000157004	PUMSUB01-A
323885 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
323890 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
323895 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
323900 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
323905 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
323910 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
323915 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
323920 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
323925 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
324347 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
324366 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
324378 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
324388 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
324398 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
324408 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
324415 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
324422 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
324441 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
324451 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
324461 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
324471 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
324477 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
324853 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02Q
325011 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
325447 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
344203 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
345343 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
353738 Analyzer Gas Quad Detector Insp/Service (6m) 5520	5520-WWSM-P-PC	0000207056	ANAGASCL-S
353744 Boiler Industrial Heating Eqmt Insp/Service (1y) 5520	5520-WWSM-F-HV	0000241329	BOILER02A
353750 Boiler Preheat Tank Water Insp/Service (1y) 5520	5520-WWSM-F-HV	0000241328	BOILER02A
353756 Grinder Muffin Monster Bar Insp/Service (1y) 5520	5520-WWSM-P-HW	0000241332	GRINDR06-A
353759 Meter Flow Digested Sludge Insp/Service (1y) 5520	5520-WWSM-P-PC	0000241336	METFLO01-A
353764 Meter Flow Thickened Was Insp/Service (1y) 5520	5520-WWSM-P-PC	0000241337	METFLO01-A
353769 Mixer Polymer Reactor Insp/Service (1y) 5520	5520-WWSM-P-SH-CHEM	0000241326	MIXSUB01-A
353775 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
353780 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
353785 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
353790 Pump Cent Lystek Prod Pump Insp/Service (1y) 5520	5520-WWSM-P-SH-CHEM	0000241346	PUMCEN09A
353809 Pump Cent Lystek Prod Pump Insp/Service (1y) 5520	5520-WWSM-P-SH-CHEM	0000241347	PUMCEN09A
353828 Pump Cent P225 Booster Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000241330	PUMCEN09A
353847 Pump Peristaltic Chemical Metering Insp/Service (3m) 5520	5520-WWSM-P-SH-CHEM	0000241327	PUMPER02

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
353864 Pump Prog Cav 01 Thickened Sludge Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000241338	PUMPRO01-A
353867 Pump Subm 01 Queen St Insp/Service (1y) 5520	5520-SPQN	0000065224	PUMSUB01-A
353876 Pump Subm 02 Queen St Insp/Service (1y) 5520	5520-SPQN	0000065223	PUMSUB01-A
353885 Pump Subm Lawn Water Insp/Service (1y) 5520	5520-WWSM-F-BG	0000207052	PUMSUB01-A
353894 Pump Twas Smart Turner Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000241340	PUMCEN11-A
353897 Pump Twas Smart Turner Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000241342	PUMCEN11-A
353900 Tank Hot Water Heater Electric Insp (1y) 5520	5520-WWSM-F-HV	0000241325	TANHOT01-A
354167 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
354172 Spill Kit Inspect (6m) 5520	5520-WWSM		SAFSPL00-S
354174 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
354179 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
354184 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
354189 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
354194 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
354199 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
354204 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
354209 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
354679 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
354698 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
354710 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
354720 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
354730 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
354740 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
354747 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
354754 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
354773 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
354783 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
354793 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
354803 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
354809 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
355216 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02M
355380 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
355405 OG110 OCWA's H&S Manual and Policy Review (1y) St Marys	5520-WWSM		FACOG110
355702 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
375625 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
376918 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
377039 Equipment Maintenance (1m) 5520	5520-WWSM-F		
377167 Blower Building Maintenance 5520	5520-WWSM-F-BG		
386038 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
386043 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
386048 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALAO2-M
386053 Pump Subm 01 Robinson St Insp/Service (1y) 5520	5520-SPRB	0000065205	PUMSUB01-A
386062 Pump Subm 02 Robinson St Insp/Service (1y) 5520	5520-SPRB	0000065206	PUMSUB01-A
386305 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
386310 Supervisor Spot Checks (3m) 5520	5520-WWSM		H&SINS06-Q
386312 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
386317 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
386322 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
386327 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
386332 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
386337 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
386342 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
386347 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
386768 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
386787 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
386799 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
386809 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
386819 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
386829 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
386836 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
386843 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
386862 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
386872 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
386882 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
386892 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
386898 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
387300 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02M
387415 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
387688 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
387853 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALAO2-M
408793 Review General Data WISKI (3m) 5520	5520-WWSM		GENDAT01-Q
408850 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
408890 Equipment Maintenance (1m) 5520	5520-WWSM-F		
409023 Replace drain cover on roof of WAS and RAW buildings 5520	5520-WWSM-F-BG		
409027 Replacement vent screen in RAS building basement 5520	5520-WWSM-F-BG		
409029 Replacement vent screen in WAS building basement 5520	5520-WWSM-F-BG		
416709 Flame Arrester Route Insp/Service (1y) 5520	5520-WWSM		FLAMEARR-A
416916 Meter Level 01 Robinson St Insp/Service (1y) 5520	5520-SPRB	0000065210	METLEV01-A
416921 Meter Level Raw Sewage Insp/Service (1y) 5520	5520-WWSM-P-PC	0000065240	METLEV01-A
416926 Meter Level Supernate Wet Well Insp/Service (1y) 5520	5520-WWSM-P-PC	0000065283	TNKWETLVL

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
416931 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
416936 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
416941 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
416946 Pump Subm 01 Raw Sewage Insp/Service (1y) 5520	5520-WWSM-P-HW	0000157009	PUMSUB01-A
416955 Pump Subm 02 Raw Sewage Insp/Service (1y) 5520	5520-WWSM-P-HW	0000207051	PUMSUB01-A
416964 Pump Subm 03 Raw Sewage Insp/Service (1y) 5520	5520-WWSM-P-HW	0000157010	PUMSUB01-A
416973 Recorder Chart Methane Gas Insp/Service (1y) 5520	5520-WWSM-P-PC	0000065270	RECCHA01-A
416975 Valve Relief Press Insp/Service (1y) 5520	5520-WWSM-P-TT	0000065358	VALRELDA-A
416978 Valve Relief Press Insp/Service (1y) 5520	5520-WWSM-P-TT	0000065364	VALRELDA-A
416981 Valve Relief Press Insp/Service (1y) 5520	5520-WWSM-P-TT	0000065365	VALRELDA-A
417334 MSDS Review - (6m) 5520	5520-WWSM		MSDSREVO1
417341 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
417346 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
417351 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
417356 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
417361 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
417366 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
417371 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
417376 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
417381 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
417833 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
417852 Grinder Communitor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
417864 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
417874 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
417884 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
417894 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
417901 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
417908 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
417927 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
417937 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
417947 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
417957 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
417963 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
418321 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02Q
418443 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
418710 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
418928 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
439599 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
448038 Mixer Subm 01 Sludge Storage Insp/Service (1y) 5520	5520-WWSM-P-SH-PIPE	0000065264	MIXSUB01-A
448044 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M

Work Order List

Site: OCWASITE

Work Order Description	Location	Asset	Job Plan
448049 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
448054 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
448271 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
448276 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
448281 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
448286 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
448291 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
448296 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
448301 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
448306 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
448311 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
448751 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
448770 Grinder Comminkutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
448782 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-A
448807 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-A
448832 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-A
448857 UV Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
448864 UV Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
448871 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
448890 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
448900 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
448910 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
448920 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
448926 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
449492 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTURO2M
449651 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
449886 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
450053 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
472300 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
482076 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
482081 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
482086 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
482091 Pump Cent Aeration Drain Insp/Service (1y) 5520	5520-WWSM-F-BG	0000065639	PUMCEN09A
482542 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
482547 Chemical System Flushing (6m) 5520	5520-WWSM		CHEMFLSH01
482550 Supervisor Spot Checks (3m) 5520	5520-WWSM		H&SINS06-Q
482552 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
482557 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
482562 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
482567 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
482572 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
482577 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
482582 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
482587 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
483162 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
483181 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04A
483197 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
483207 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
483217 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
483227 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVLGBTBK
483246 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVLGBTBK
483265 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
483284 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09A
483303 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09A
483322 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09A
483341 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
483347 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
483766 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02M
483915 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
484363 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
484552 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
506955 Review General Data WISKI (3m) 5520	5520-WWSM		GENDAT01-Q
507012 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
516258 Blower Centrifugal 01 Aeration Insp/Service (1y) 5520	5520-WWSM-P-ST-AERA	0000065469	BLOWER05-A
516264 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
516269 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
516274 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
516824 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
516829 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
516834 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
516839 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
516844 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
516849 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
516854 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
516859 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
516864 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
517315 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
517334 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
517346 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
517356 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
51736 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
517376 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
517383 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
517390 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M
517409 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCEN09M
517419 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCEN09M
517429 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCEN09M
517439 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
517445 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
517977 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTUR02A
518097 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
518372 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
518531 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
541645 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
549681 Analyzer Gas Quad Detector Insp/Service (6m) 5520	5520-WWSM-P-PC	0000207056	ANAGASCL-S
549687 Filter Air 01 Carbon Sludge Insp/Service (1y) 5520	5520-WWSM-P-ST-AERA	0000065259	FILCAR01
549696 Alarm Dialer Testing (1m) 5520	5520-WWSM-P-PC	0000065544	PANALA02-M
549701 Alarm Dialer 01 Queen PS Testing (1m) 5520	5520-SPQN	0000065226	PANALA02-M
549706 Alarm Dialer 01 Robinson PS Testing (1m) 5520	5520-SPRB	0000065211	PANALA02-M
549711 Pump Rot Lobe 01 Digester Insp/Service (1y) 5520	5520-WWSM-P-TT	0000207053	PUMROTL02
549921 PH Probe Insp/Calib (1m) 5520	5520-WWSM		ANALPH01-M
549926 Spill Kit Inspect (6m) 5520	5520-WWSM		SAFSPL00-S
549928 Do Probe Calibration (1y) 5520	5520-WWSM		ANAD003A
549939 Daily O&M Activities Emily Pumping Station (1m) 5520	5520-SPEM		FACINS01-W
549944 TPM Insp/Maint Emily Pumping Station (1m) 5520	5520-SPEM		FACWKL-M
549949 Daily O&M Activities Queen Pumping Station (1m) 5520	5520-SPQN		FACINS01-W
549954 TPM Insp/Maint Queen Pumping Station (1m) 5520	5520-SPQN		FACWKL-M
549959 Daily O&M Activities Robinson Pumping Station (1m) 5520	5520-SPRB		FACINS01-W
549964 TPM Insp/Maint Robinson Pumping Station (1m) 5520	5520-SPRB		FACWKL-M
549969 Daily O&M Activities St Marys WWTP (1m) 5520	5520-WWSM		FACINS01-W
549974 TPM Insp/Maint St Marys WWTP (1m) 5520	5520-WWSM		FACWKL-M
550450 Engine Diesel Queen St PS Insp/Test (1m) 5520	5520-SPQN	0000065231	ENGDIE02-M
550469 Engine Diesel Queen St PS Insp/Service (1y) 5520	5520-SPQN	0000065231	ENGDIE02-A
550508 Grinder Comminutor 01 Influent Insp/Service (1m/1y) 5520	5520-WWSM-P-HW	0000065330	GRINDER04M
550520 Tank Clarifier 01 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065403	TANPRO11-M
550530 Tank Clarifier 03 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065420	TANPRO11-M
550540 Tank Clarifier 04 Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-CLAR	0000065498	TANPRO11-M
550550 Uv Light Bank 02 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065526	UVREA02-M
550557 Uv Light Bank 01 Effluent Insp/Clean/Service (1m/1y) 5520	5520-WWSM-P-DI	0000065527	UVREA02-M
550564 Engine Diesel St. Mary's WWTP Insp/Test (1m) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-M

Work Order List

Site: OCWASITE

Work Order Description	Location:	Asset	Job Plan
550583 Engine Diesel St. Mary's WWTP Insp/Service (1y) 5520	5520-WWSM-F-PG	0000065531	ENGDIE02-A
550622 Pump Cent 01 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065561	PUMCENO9M
550632 Pump Cent 02 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000065563	PUMCENO9M
550642 Pump Cent 03 Return Sludge Insp/Service (1m/1y) 5520	5520-WWSM-P-ST-PIPE	0000065585	PUMCENO9M
550652 Pump Rot Lobe Insp/Service (1m/1y) 5520	5520-WWSM-P-TT	0000207020	PUROTLOB02
550658 Engine Diesel Robinson St PS Insp/Test (1m) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-M
550677 Engine Diesel Robinson St Insp/Service (1y) 5520	5520-WWSM-F-PG	0000269085	ENGDIE02-A
551068 Blower Cent Turbo Insp/Service (1m/3m/1y) 5520	5520-WWSM-P-ST-AERA	0000269084	BLOTURO2M
551150 Confined Space Hazard Assessment Review (1y) St Marys Cluster	5520-WWSM		CONSPC01-A
551234 OG15 Facility OHSA Inspection (1m) 5520	5520-WWSM		FACOG15-M
551520 Sampling and Testing (1m) 5520	5520-WWSM		SAMPLE01-M
551682 Alarm Dialer 01 Emily St. PS Testing (1m) 5520	5520-SPEM	0000269089	PANALA02-M
578506 Sampling Calendar Review (1y) 5520	5520-WWSM		SAMPLE02-A
578565 WISKI Review (1m) 5520	5520-WWSM		FACREV01-M
579735 Supervisor Spot Checks (3m) 5520	5520-WWSM		

Number of Records: 455



Wastewater Annual Summary Report
Reporting Year - 2017

APPENDIX C
NOTICE OF MODIFICATIONS



Notice of Modification to Sewage Works

RETAIN COPY OF COMPLETED FORM AS PART OF THE ECA AND SEND A COPY TO THE WATER SUPERVISOR (FOR MUNICIPAL) OR DISTRICT MANAGER (FOR NON-MUNICIPAL SYSTEMS)

Part 1 – Environmental Compliance Approval (ECA) with Limited Operational Flexibility

(Insert the ECA's owner, number and issuance date and notice number, which should start with "01" and consecutive numbers thereafter)

ECA Number 4934-AH9S98	Issuance Date (mm/dd/yy) 02/24/17	Notice number (if applicable) N/A
ECA Owner The Town of St. Marys	Municipality The Town of St. Marys	

Part 2: Description of the modifications as part of the Limited Operational Flexibility

(Attach a detailed description of the sewage works)

The existing Water Pollution Control Plant in St. Marys has several sludge storage tanks which are noted in the current ECA. The ECA also notes a "sump pump". This sump pump was designed to periodically empty the sludge storage tanks into haul trucks and was designed as a 10HP submersible sewage pump that was selected to have a rated capacity of approx. 50L/s. The viscosity of the sludge material is much thicker than water (i.e. viscosity of approx. 4500 centipose) and as a result the sludge pump was only operating at approx. 10L/s and frequently running into maintenance issues. This pump is being replaced by a 40HP progressive cavity pump designed to operate at approx. 34L/s @ 9.4 m TDH. The pump is manufactured by Netzsch Canada Inc.

Drawings and system curve information is available upon request.

Description shall include:

1. A detail description of the modifications and/or operations to the sewage works (e.g. sewage work component, location, size, equipment type/model, material, process name, etc.)
2. Confirmation that the anticipated environmental effects are negligible.
3. List of updated versions of, or amendments to, all relevant technical documents that are affected by the modifications as applicable, i.e. submission of documentation is not required, but the listing of updated documents is (design brief, drawings, emergency plan, etc.)

Part 3 – Declaration by Professional Engineer

I hereby declare that I have verified the scope and technical aspects of this modification and confirm that the design:

1. Has been prepared or reviewed by a Professional Engineer who is licensed to practice in the Province of Ontario;
2. Has been designed in accordance with the Limited Operational Flexibility as described in the ECA;
3. Has been designed consistent with Ministry's Design Guidelines, adhering to engineering standards, industry's best management practices, and demonstrating ongoing compliance with s.53 of the Ontario Water Resources Act; and other appropriate regulations.

I hereby declare that to the best of my knowledge, information and belief the information contained in this form is complete and accurate

Name (Print) Ryan P. DeVries	PEO License Number 100183886
Signature 	Date (mm/dd/yy) 09/26/17
Name of Employer B. M. Ross and Associates Limited	

Part 4 – Declaration by Owner

I hereby declare that:

1. I am authorized by the Owner to complete this Declaration;
2. The Owner consents to the modification; and
3. This modifications to the sewage works are proposed in accordance with the Limited Operational Flexibility as described in the ECA.
4. The Owner has fulfilled all applicable requirements of the Environmental Assessment Act.

I hereby declare that to the best of my knowledge, information and belief the information contained in this form is complete and accurate

Name of Owner Representative (Print) Dave Blake	Owner representative's title (Print) Environmental Services Supervisor
Owner Representative's Signature 	Date (mm/dd/yy) 09/27/17